



No.DJB/QCLTYR/PD/260507

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2026.....

DATE: - 25-05-2026

Analysis report of water samples collected from ((1) Inlet (Bore water), (2) Outlet (After R.O) of DELHI INTERNATIONAL SCHOOL, LONI ROAD, JAWAHAR NAGAR, JOHRIPUR, DELHI-94 for drinking purpose.

Ref. No. - DISS/GEN/1009/26,
Challan No: - 60,

dated: - 11.05.2026
dated: - 18.05.2026

ACWA-TYR

Diary No. 151 dated 01.06.2026

Date of collection: 22.05.2026

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	UNOBJ.	UNOBJ.
3.	Turbidity	1.0	5.0	NTU	0.42	0.31
4.	pH Value	6.5-8.5	--	-	7.4	6.8
5.	Electrical Conductivity	--	--	µs/cm	3388	170
6.	Total Dissolved Solids	500	2000	mg/l	2202	110
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	474	16
9.	Total Hardness	200	600	mg/l	630	14
10.	Calcium as (Ca)	75	200	mg/l	114.4	4.0
11.	Magnesium as (Mg)	30	100	mg/l	82.56	0.96
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	...	...	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	99.16	11.84
15.	Sulphate	200	400	mg/l	506.83	6.37
16.	Chloride	250	1000	mg/l	508	30
17.	Fluoride	1.0	1.5	mg/l	0.60	0.12
18.	Dissolved Iron	1.0	NR	mg/l	0.10	0.10
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	NIL	NIL
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	28	0

REMARKS:- (1) On the basis of above tested parameters, water sample (1) does not conform to the prescribed limits and cannot be considered fit for drinking purpose.
(2) On the basis of above tested parameters, water sample (2) conforms to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikh Lal)
ACWA(TYR)

(A.G. Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST

Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93

Vice Principal
Delhi International Sec. School
Main Loni Road,
Jawahar Nagar, Delhi-110094

Manager
Delhi International Sec. School
Main Loni Road, Jawahar Nagar
Johripur, Delhi - 110094

MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE

No. DHO/Shah (N)/2025/D-603


Dated: 24/10/25

SCHOOL INSPECTION REPORT


In reference to your application duly submitted in the office of undersigned vide diary no. 1041 dated 23.10.2025, the inspection of "DELHI INTERNATIONAL SEC. SCHOOL" at Main Loni Road, Jawahar Nagar, Johripur, Delhi-110094 was carried out on dated 24.10.2025. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions, provision of latrines & urinals is sufficient according to the number of students and has safe drinking water facilities for the students and members of staff of the institution.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

Manager
DELHI INTERNATIONAL SEC. SCHOOL
Main Loni Road, Jawahar Nagar
Johripur, Delhi-110094


Dy. Health Officer
Shahdara North Zone

सुप-स्वास्थ्य अधिकार
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम


Vice Principal
Delhi International Sec. School
Main Loni Road,
Jawahar Nagar, Delhi-110094


Manager
Delhi International Sec. School
Main Loni Road, Jawahar Nagar
Johripur, Delhi - 110094